

CERTIFICATE OF CALIBRATION / VALIDATION

Customer	TheSearleCompany Ltd	Certificate #	MVLT_COC_011122_270
Address	F-319, S.I.T.E Karachi	Date of Issue	17-10-22
E mail	Mustafain.baig@searlecompany.com	Date of Expiry	16-04-23

Unit Under Test UUT			
User ID	AM-CU-017	Sub Location	OSD DUST COLLECTORS #03
Location	CENTRAL UTILITY	Instrument Type	Ampere Meter
Model	ELMEASURE	Make	ELMEASURE
Range	0-500 AMP	Accuracy/Resolution	1 AMP
Serial #	N/A	Condition	PASS
Least Count	1 AMP	Tolerance Limit	± 1 AMP

Master / Testing / Reference Equipment Used			
Digital Clamp Meter			
Model	UT207B	Serial #	203561411
Range	0-1000 AMP	Accuracy	0.1 AMP
Traceability Ref #	ILS/0322/178/02	Cal Due date	2023-03-04

Test Performed / Readings			
Master Reading	UUT Readings	Difference	Review
AMP	AMP	AMP	AMP
100	100	0.00	PASS
200	200	0.00	PASS
300	300	0.00	PASS
400	400	0.00	PASS

*UUT = Unit under Test * N/A= Not applicable

Remarks: Above given Ampere Meter working as per manufacture specifications.



Noman Khan (Test Eng.)

*PNAC: ISO 17025 Certified Assessor
ISO/IEC17025/APLACTR001*

Company Stamp

TheSearleCompany Representative